

TOWN BOARD OF HEALTH
Town of Horicon
PO Box 90, Brant Lake, NY 12815
(518) 494-3647

NOTICE OF PUBLIC HEARING

Pursuant to Article V, Section E, of the Town of Horicon Sanitary Regulations, NOTICE IS HEREBY GIVEN, that the Horicon Town Board of Health will conduct a Public Hearing on Thursday, April 21, 2016 at 7:00 PM at the Horicon Community Center, 6604 State Rt. 8, Brant Lake, NY.

The Public Hearing is for a variance to install a septic system at 3534 East Schroon River Rd, Brant Lake, NY, Tax Map #70.15-1-9, which cannot meet the minimum setback requirements of Article III, Section D of the Horicon Sanitary Regulations. The owner, represented by Hutchins Engineering, proposes to replace the current drywell system which does not meet the necessary separation distances from the property line or the Schroon River. The proposed septic tank and absorption field will require variances for the following separation distances:

Septic tank to property line – 10' required, 2' proposed

Septic tank to dwelling – 10' required, 3' proposed

Absorption field to property line – 10' required, 5' proposed

Absorption field to dwelling – 20' required, 5' proposed

All documents pertinent to said application may be viewed by contacting the Horicon Zoning Office at 6604 State Rt. 8, Brant Lake, NY during regular business hours.

By Order of the Horicon Town Board of Health

Krista Wood, Town Clerk