

TOWN BOARD OF HEALTH  
Town of Horicon  
PO Box 90, Brant Lake, NY 12815  
(518) 494-3647

### **NOTICE OF PUBLIC HEARING**

Pursuant to Article V, Section E, of the Town of Horicon Sanitary Regulations, NOTICE IS HEREBY GIVEN, that the Horicon Town Board of Health will conduct a Public Hearing on Thursday, July 20, 2017 at 7:00 PM at the Horicon Community Center, 6604 State Rt. 8, Brant Lake, NY.

The Public Hearing is for a variance to replace a failed septic system at 211 East Shore Drive, Adirondack, NY, Tax Map #36.3-3-12.1, which does not meet the minimum setback requirements of Article III, Section D of the Horicon Sanitary Regulations. The owner, represented by Harold Berger, PE, proposes to replace the failed existing septic system with a Presby Advanced Enviro-Septic (AES) Treatment System which does not meet the necessary separation distance from the mean high-water mark of Schroon Lake. The AES treatment system will sit 72 feet from the mean high-water mark of Schroon Lake where 100 feet is required.

All documents pertinent to said application may be viewed by contacting the Horicon Zoning Office at 6604 State Rt. 8, Brant Lake, NY during regular business hours.

**By Order of the Horicon Town Board of Health**  
Krista Wood, Town Clerk